

SNDT Women's University
1, Nathibai Thackersey Road,
Mumbai 400 020
Phone: +91 22 2203 1879
Fax: +91 22 2201 8228



श्रीमती ना. दा. ठाकरसी विद्यापीठ
१, नाथीबाई ठाकरसी मार्ग
मुंबई ४०० ०२०
Telegram: UNIWOMEN
Website: sndt.ac.in

May 27, 2021

Estate Dept./2021-22 / (Not.3)/45

Sub: Quotation for Replacement of Old light points with New light points at Ground floor in Library at SNDT Women's University, Juhu Campus..

Madam/Sir,

Sealed quotations are invited for Replacement of Old light points with New light points at Ground floor in Library at SNDT Women's University, Juhu Campus. Interested authorized vendors are supposed to submit their quote along with their detail profile in the format given in "Annexure A" on their company letter head. Quotation should be submitted to the Office of "The Registrar" at Churchgate campus on or before 01st June 2021 Contractor should submit their.

- i) GST No.
- ii) PAN no.
- iii) Client List,
- iv) Company profile,
- v) Last 3 years audited profit lost statement along with Quotation

Quotation should be submitted in closed envelop and on top write the subject.

The University reserves the right to reject any or all quotations without assigning any reasons thereof.

(Dr. Meera Desai)
Registrar(Addl.Charge)

SNDT Women's University

1, Nathibai Thackersey Road,

Mumbai 400 020

Phone: +91 22 2203 1879

Fax: +91 22 2201 8226



श्रीमती ना. दा. ठाकरसी विद्यापीठ

१, नाथीबाई ठाकरसी मार्ग

मुंबई ४०० ०२०

Telegram: UNIWOMEN

Website: sndt.ac.in

(Offer should filled on letter head)

Annexure A

To,
The Registrar
SNDT Women's University,
Churchgate, Mumbai

Sub: Quotation Replacement of Old light points with New light points at Ground floor in Library at SNDT Women's University, Juhu Campus.

Respected Madam/Sir,

With reference to subject cited above we would like to furnish our quote with best rate possible as below:

Sr. No.	Description of Item	Qty	Unit	Rate	Amount
01	Point wiring in PVC trunking (casing-capping) with 1.5 sq.mm (2+1E) FRLSH grade copper wire, modular type switch, earthing and required accessories as per specification No: WG-PW/SW FOR LIGHT POINTS	140	Point		
02	Dismantling the existing light, fan, bell, clock, independent plug point, wiring including circuit mains of all types along with accessories etc. complete as per specification No: WG-DM/PW	210	Point		
03	Dismantling the existing aluminium /copper mains, submains wiring upto 10 sq.mm. along with accessories etc complete as per specification No: WG-DM/PW	1900	m		
04	Supplying & erecting LED 20W tube light fitting (4 feet) with aluminium housing, heat sink, integrated HF electronic driver complete.	140	Point		
05	Supplying & fixing anchor type fastener fan hook, with 2 nos. of 10 mm dia x 75 mm long with necessary materials for ceiling fan.	66	Each		
06	Supplying and erecting fan clamp of 30 x 5 mm. M.S. flat of required length and 10 mm. M.S. bolt and nuts erected with necessary hook of 10 mm. M.S. round bar and painted.	66	Each		

SNDT Women's University
1, Nathibai Thackersey Road,
Mumbai 400 020
Phone: +91 22 2203 1879
Fax: +91 22 2201 0226



श्रीमती ना. दा. ठाकरसी विद्या,
१, नाथीबाई ठाकरसी मार्ग
मुंबई ४०० ०२०
Telegram: UNIWOMEN
Website: sndt.ac.in

07	Supplying and erecting regular/ standard model ceiling fan of 1400mm. sweep complete erected in position as per specification no. FG-FN/CF	18	Each		
	Total				

All the terms and conditions given in notifications are studied thoroughly and accepted fully.

Thanking You,

Yours Faithfully,

Name of Company

Signature of the Proprietor

Date:

Note: Enclose GST number, PAN number, declaration if GST is not applicable